

Multifamily Electrification


Electrical Infrastructure Case Studies

Jack Aitchison, AEA

December 7th, 2023

Agenda

- Multifamily Electrical Infrastructure
- Case Studies:
 - **High Rise Example**
 - Avoiding a Service Upgrade
 - **Low Rise Example**
 - Avoiding Subpanel Upgrades



Metering Configuration

Master Metered

Direct Metered

Sub Metered

Utility

Building

Apartments

Utility




Building

Apartments

Utility

Building

Apartments



High Rise Full Electrification

- Santa Ana, CA | Built 1984
- 11 stories, 199 apartments
- Central gas DHW
- 2 pipe heating and cooling
- Chiller and gas boiler
- Limited electrical capacity
- Master Metered


SOW:

- Reversible Chiller to provide hydronic heating and cooling
- Central Heat Pump Water Heater for DHW



NEC Approved Electrical Load Monitoring Study

- Alternative approach to NEC Deemed Calculations
- Utilize actual demand rather than calculated demand to determine existing electrical load and available electrical capacity
- Often more favorable results compared to the calculated demand/load analysis



High Rise Full Electrification

- Max demand calculation approach
- 12 months of bills reviewed
- 218 KW peak demand (summer)
- =254 amps available capacity

EXISTING LOAD CALCULATION			
CKT	LOAD DESCRIPTION	KW	KVA
	EXISTING LOAD MAX DEMAND PER 12 MONTH SCE	218.0	
	218.0 KW / 0.80 PF		272.5
	25% FACTOR (NEC 220.87) ON MAX DEMAND PER 12 MONTH SCE		68.1
TOTAL KVA			340.6
946 AMP @ 208 / 120 V, 3 P / 4 W , 60HZ			
EXISTING SERVICE SIZE = 1200A @ 208/120V, 3PH, 4W			

High Rise Full Electrification

- First pass at calculation
- Adds in CHPWH Plant
- Assumes worst case load
- Exceeds 1200 amp service

EXISTING LOAD CALCULATION			
CKT	LOAD DESCRIPTION	KW	KVA
	EXISTING LOAD MAX DEMAND PER 12 MONTH SCE	218.0	
	218.0 KW / 0.80 PF		272.5
	25% FACTOR (NEC 220.87) ON MAX DEMAND PER 12 MONTH SCE		68.1
1	New HP Water Heater	77.0	96.3
2	NEW ADDED PLUMBING LOAD		
3	25% OF LARGEST MOTOR		24.1
TOTAL KVA		460.9	
1280 AMP @ 208 / 120 V, 3 P / 4 W, 60HZ EXISTING SERVICE SIZE = 1200A @ 208/120V, 3PH, 4W			

High Rise Full Electrification

- Second pass at calculation
- Credit for more efficient HP Chiller
 - Existing = 590 amps
 - New = 490 amps (36 kVA)
- Just meets service capacity

Other Upgrades?

- LED Lighting Retrofit
- Ventilation Upgrades

EXISTING LOAD CALCULATION			
CKT	LOAD DESCRIPTION	KW	KVA
	EXISTING LOAD MAX DEMAND PER 12 MONTH SCE	218.0	
	218.0 KW / 0.80 PF		272.5
	25% FACTOR (NEC 220.87) ON MAX DEMAND PER 12 MONTH SCE		68.1
1	REMOVED BOILER HVAC LOADS		-1.2
2	DELTA, REVISED HVAC PUMPS		11.1
3	DELTA, REVISED CHILLER		-36.0
4	DELTA, REV. AHU + SPLITS + EFS		11.1
5	NEW ADDED SWING TANK		36.0
6	NEW ADDED HP WATER HEATER		57.0
7	25% OF LARGEST MOTOR		6.3
		TOTAL KVA	424.8
1180 AMP @ 208 / 120 V, 3 P / 4 W, 60HZ			
EXISTING SERVICE SIZE = 1200A @ 208/120V, 3PH, 4W			

Low Rise Full Electrification

- Sunnyvale, CA | Built 1994
- 3 stories, 121 SRO apartments, 1 on-site Manager Apartment
- Central combi gas boiler providing DHW & Space Heating
- Limited electrical capacity
- Master Metered
- Units do not have their own Kitchen

SOW:


- In-unit HVAC Electrification with Packaged Terminal Heat Pump (PTHP)
- Central Heat Pump Water Heater for DHW



Subpanel

Utility Meter

Service Disconnect



ONE LINE DIAGRAM

PANEL : 1B		VOLTS.: 3φ 4W 120/200V			
MTG.:		MAIN BRK :			
TYPE : MLD		BUS : 225A			
LOAD	DESCRIPTION	BRK #	BRK #	DESCRIPTION	LOAD
1200	#114 MICROWAVE & FRIG	20/1	20/1	#121 MICROWAVE & FRIG	1200
1500	#114 SMALL APPLIANCE	3	4	#121 SMALL APPLIANCE	1500
1355	#114 RECEPT & LTS	5	6	#121 RECEPT & LTS	1355
1200	#115 MICROWAVE & FRIG	7	8	#122 MICROWAVE & FRIG	1200
1500	#115 SMALL APPLIANCE	9	10	#122 SMALL APPLIANCE	1500
1355	#115 RECEPT & LTS	11	12	#122 RECEPT & LTS	1355
1200	#116 MICROWAVE & FRIG	13	14	#123 MICROWAVE & FRIG	1200
1500	#116 SMALL APPLIANCE	15	16	#123 SMALL APPLIANCE	1500
1355	#116 RECEPT & LTS	17	18	#123 RECEPT & LTS	1355
1200	#117 MICROWAVE & FRIG	19	20	#124 MICROWAVE & FRIG	1200
1500	#117 SMALL APPLIANCE	21	22	#124 SMALL APPLIANCE	1500
1355	#117 RECEPT & LTS	23	24	#124 RECEPT & LTS	1355
1200	#118 MICROWAVE & FRIG	25	26	#125 MICROWAVE & FRIG	1200
1500	#118 SMALL APPLIANCE	27	28	#125 SMALL APPLIANCE	1500
1355	#118 RECEPT & LTS	29	30	#125 RECEPT & LTS	1355
1200	#119 MICROWAVE & FRIG	31	32	#113 GARBAGE DISPSER	1200
1500	#119 SMALL APPLIANCE	33	34	#114 " " "	1200
1355	#119 RECEPT & LTS	35	36	#115 " " "	1200
1200	#120 MICROWAVE & FRIG	37	38	#116 " " "	1200
1500	#120 SMALL APPLIANCE	39	40	#117 " " "	1200
1355	#120 RECEPT & LTS	41	42	#118 " " "	1200



CIRCUIT DIRECTORY HPIB

1 114 114 micro	2 121 micro
3 114 small app.	4 121 small app
5 114 Recept. lights	6 121 Recept lights
7 115 micro	8 122 micro
9 115 small app	10 122 small app
11 115 Recept. lights	12 122 Recept. lights
13 116 micro	14 123 micro
15 116 Recept. lights	16 123 small app
17 116 small app	18 123 Recept. lights
19 117 micro	20 124 micro
21 117 Recept lights	22 124 small app
23 117 small app	24 124 Recept. lights
25 118 micro	26 125 micro
27 118 small app	28 125 small app.
29 118 Recepts. lights	30 125 Recepts. lights
31 119 micro	32 113 Garb. Disp
33 119 small APP	34 114 " " "
35 119 Recepts lights	36 115 " " "
37 120 micro. Frig	38 116 " " "
39 120 small app	40 117 " " "
41 120 Recepts lights	42 118 " " "

114B361HO1

Existing Circuits in Each Dwelling Unit:

- Microwave/Mini Fridge
- Lighting and Receptacles
- Small Appliance
- Garbage Disposal
- No Available PTHP






Figure 4: Dwelling unit electrical




Proposed Circuits in Each Dwelling Unit:

- Microwave/Mini Fridge/Small Appliances
- Lighting and Receptacles
- **PTHP**
- Garbage Disposal

Other Options?

- Smart Splitter/Circuit Sharer
- Garbage Disposal/Small Appliance Circuit





Thank You!
